



**ADDENDUM #1 – JULY 8, 2022
REQUEST FOR PROPOSALS
ON-CALL HVAC SERVICES**

Commission Contact: Todd Gibbs
Director of Operations
Phone: (319) 731-5718
Fax: (319) 362-1670
T.Gibbs@flyCID.com

This Addendum is added to and shall become a part of the Request for Proposals (RFP) documents dated June 30, 2022. Proposers shall acknowledge receipt of this Addendum on the Signature Page. Failure to comply may result in rejection of the Proposal.

Note:	The Response Due Date <u>has not</u> been changed.	Due Date:	July 13, 2022
	The Response Time <u>has not</u> been changed.	Time Due:	2:00 PM (CDT)

❖ **This Addendum consists of the following:**

Questions and Answers:

1. List of equipment one may be working on?

Answer:

- 80 – 90 heat pumps (most are under 10T) includes Tranes, Daikins, McQuay and Enercon; heat pumps are fed from 2 large pumps on a lead lag
- Three 20-25T splits
- Nine 30-60T package units, one on each jet bridge, controlled from a PLC
- Several mini-splits
- Four Thermal Solutions boilers at 2 million BTU's a piece
- Two cooling towers
- Two ice melt systems covering 8,000 sq. ft. (fed from the Thermal Solution boilers)
- Two AAON 60T units
- 2 large water heaters
- Five 50HP Armstrong pumps
- Tube heaters in multiple buildings
- 4 new Daiken RTU's in a separate building
- In most cases, plumbing is taken care of in-house.

Acknowledge receipt of this Addendum on the Signature Page.